

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/09/2011  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155703</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 , 04</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>09/07/2011</b>	
NAME OF PROVIDER OR SUPPLIER  <b>BROOKSIDE VILLAGE INC</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>1111 CHURCH AVE JASPER, IN 47546</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 09/07/11</p> <p>Facility Number: 003240 Provider Number: 155703 AIM Number: NA</p> <p>Surveyor: Lex Brashear, Life Safety Code Specialist</p> <p>At this Life Safety Code survey, Brookside Village Inc. was found in compliance with Requirements for Participation in Medicare, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The existing portion of the facility which was surveyed using Chapter 19, Existing Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors, and all resident rooms. The facility has a capacity of 27 and had a census of 18 at the time of this survey.</p> <p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 09/08/11.</p>			K 000			
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code Recertification and State</p>			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/09/2011  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155703</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 , 04</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>09/07/2011</b>	
NAME OF PROVIDER OR SUPPLIER  <b>BROOKSIDE VILLAGE INC</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>1111 CHURCH AVE JASPER, IN 47546</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>Continued From page 1</p> <p>Licensure Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 09/07/11</p> <p>Facility Number: 003240 Provider Number: 155703 AIM Number: NA</p> <p>Surveyor: Lex Brashear, Life Safety Code Specialist</p> <p>At this Life Safety Code survey, Brookside Village Inc. was found in compliance with Requirements for Participation in Medicare, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The 2010 addition consisted of resident rooms 201 through 208 which was surveyed with Chapter 18, New Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors, and all resident rooms. The facility has a capacity of 27 and had a census of 18 at the time of this survey.</p>			K 000			